

# Particle sampling in Rooms 232, 310 312 and hallway in Williamson Hall 03/29/2019

Building	WAL	RM #	Outside	Ave	Building	WAL	RM #	232	Ave	Building	WAL	RM #	310	Ave
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	58754	59478	62091	60108	0.3	15432	14733	14273	14813	0.3	8346	8111	7960	8139
0.5	2755	2960	3056	2924	0.5	536	525	469	510	0.5	255	321	260	279
1	302	371	293	322	1	52	53	50	52	1	36	37	30	34
2.5	164	263	191	206	2.5	40	70	68	59	2.5	46	43	34	41
5	35	52	35	41	5	26	27	32	28	5	18	16	16	17
10	10	8	4	7	10	28	17	15	20	10	14	8	7	10
Temp	55				Temp	73				Temp	74			
RH	39				RH	29				RH	28			

Building	WAL	RM #	312	Ave	Building	WAL	RM #	232	Ave	Building	WAL	RM #	Hall	Ave
													in front of 232	
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	8041	8162	8081	8095	0.3	12985	13711	12787	13161	0.3	27419	26560	25808	26596
0.5	296	328	308	311	0.5	442	472	451	455	0.5	939	947	887	924
1	62	80	78	73	1	37	64	55	52	1	47	63	57	56
2.5	107	137	117	120	2.5	10	72	73	52	2.5	27	16	21	21
5	42	50	43	45	5	2	29	37	23	5	6	5	2	4
10	17	23	33	24	10	8	13	11	11	10	0	2	1	1
Temp	74				Temp	74				Temp	73			
RH	28				RH	28				RH	29			