

The following samples were collected from MAR Hall rooms:

- 114
- 151G
- 228
- 238

Martin Hall Particle Counts 4/10/2019

Building	MAR	RM #	Outside	Time	Building	MAR	RM #	238	Time	Building	MAR	RM #	228	Time
								or 338						
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	9946	9418	10194	9853	0.3	7163	7269	7368	7267	0.3	7947	7715	7609	7757
0.5	1053	1118	1092	1088	0.5	692	640	636	656	0.5	807	811	908	842
1	226	295	292	271	1	228	151	207	195	1	312	289	391	331
2.5	111	104	114	110	2.5	161	105	124	130	2.5	397	323	505	408
5	13	61	10	28	5	30	37	33	33	5	189	139	214	181
10	4	25	4	11	10	40	19	36	32	10	66	48	79	64
Temp	58				Temp	70				Temp	71			
RH	43				RH	30				RH	30			
Building	MAR	RM #	Hall Door	Time	Building	MAR	RM #	114	Time	Building	MAR	RM #	151G	Time
			ToWAL 2nd fl											
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	6387	6401	6021	6270	0.3	6458	6652	6749	6620	0.3	7303	6923	6797	7008
0.5	579	515	519	538	0.5	583	584	557	575	0.5	684	540	568	597
1	90	89	74	84	1	104	123	130	119	1	134	150	122	135
2.5	58	62	41	54	2.5	96	101	135	111	2.5	99	77	88	88
5	14	16	6	12	5	26	42	44	37	5	26	23	19	23
10	6	10	5	7	10	15	12	28	18	10	29	13	18	20
Temp	72				Temp	71				Temp	73			
RH	29				RH	29				RH	29			