


## Responsibilities

**Residential/Community Advisors** must check the fire extinguishers in their area weekly to ensure they are present and show no signs of damage. Any missing or damaged extinguishers must be reported to the Work Order Desk so that they can be replaced or fixed.

**The Residential Life Coordinators** should collect the inspection sheets from the Residential/Community Advisors monthly and send them to the Fire Protection Engineer. They can be mailed to Mike Lunneborg in ROZ 101 or scanned and emailed to [mlunneborg@ewu.edu](mailto:mlunneborg@ewu.edu).

## Instructions

1. Perform weekly inspections of fire extinguishers; ensure that:
  - a. The extinguisher is in the correct location
  - b. It doesn't appear damaged (e.g. dents or corroded body)
  - c. The Pin and Tamper Seal are in place
  - d. The indicator gauge, when present, is in the green segment
  - e. There is no sign of discharge



2. For the first inspection of every month, sign the Inspection Card on the extinguisher.



Inspection Card, front and back

3. Report any damage, discharge, defects, or missing extinguishers promptly to the Work Order Desk at 359-2245.

If you have any questions, contact the Fire Protection Engineer at 359-4576 or Environmental Health and Safety at 359-6496.

\_\_\_\_\_ / \_\_\_\_\_ Inspected  
 Month Year

Location	Type	Size	Initial	Date	Initial	Date	Initial	Date	Initial	Date
5 <sup>th</sup> Floor, By Rm 529	ABC									
5 <sup>th</sup> Floor, By Rm 513	ABC									
5 <sup>th</sup> Floor, By Rm 506	ABC									
5 <sup>th</sup> Floor, By Rm 550	ABC									
5 <sup>th</sup> Floor, By Rm 564	ABC									
4 <sup>th</sup> Floor, By Rm 464	ABC									
4 <sup>th</sup> Floor, By Rm 450	ABC									
4 <sup>th</sup> Floor, By Rm 406	ABC									
4 <sup>th</sup> Floor, By Rm 413	ABC									
4 <sup>th</sup> Floor, By Rm 429	ABC									
3 <sup>rd</sup> Floor, By Rm 330	ABC									
3 <sup>rd</sup> Floor, By Rm 313	ABC									
3 <sup>rd</sup> Floor, By Rm 306	ABC									
3 <sup>rd</sup> Floor, By Rm 350	ABC									
3 <sup>rd</sup> Floor, By Rm 364	ABC									
2 <sup>nd</sup> Floor, By Rm 264	ABC									
2 <sup>nd</sup> Floor, By Rm 250	ABC									
2 <sup>nd</sup> Floor, By Rm 230	ABC									
2 <sup>nd</sup> Floor, By Rm 213	ABC									
2 <sup>nd</sup> Floor, By Rm 206	ABC									
Lobby by Great Rm	ABC									

Location	Type	Size	Initial	Date	Initial	Date	Initial	Date	Initial	Date
Lobby by AC Office (113)	ABC									

**Send completed forms to: Fire Protection Engineer, ROZ 101  
or email: [mlunneborg@ewu.edu](mailto:mlunneborg@ewu.edu)**