

The following samples were collected from Williamson Hall rooms:

- 123
- 232
- 310
- 311B
- 314
- 3rd floor hallway
- Air intake on the roof

MAR_WLM Air Particulate Sampling 5/8/18

Building	RM #			Time	Building	RM #			Time	Building	RM #			Time
WLM	3rd Fl Hallway	3rd Fl Hallway	3rd Fl Hallway	14:39-14:45	WLM	314	314	314	14:48-14:52	WLM	310	310	310	15:00-15:04
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	20690	17306	16546	18180.67	0.3	15783	15427	15349	15519.67	0.3	14279	14029	14016	14108.00
0.5	881	822	565	756.00	0.5	539	553	553	548.33	0.5	498	515	526	513.00
1	187	231	106	174.67	1	83	129	126	112.67	1	118	125	152	131.67
2.5	132	183	75	130.00	2.5	89	97	135	107.00	2.5	124	144	170	146.00
5	35	29	16	26.67	5	25	29	36	30.00	5	46	61	57	54.67
10	45	38	13	32.00	10	22	21	34	25.67	10	34	60	52	48.67
Temp	73.8			73.8	Temp	73			73	Temp	72.8			72.8
RH	40.7			40.7	RH	39.9			39.9	RH	40.4			40.4

Building	RM #			Time	Building	RM #			Time	Building	RM #			Time
WLM	311B	311B	311B	15:34-15:40						WLM	Roof @ Pent Int	Roof @ Pent Int	Roof @ Pent Int	15:34-15:40
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	14303	14534	14234	14357.00	0.3				#DIV/0!	0.3	42050	42153	41952	42051.667
0.5	496	560	525	527.00	0.5				#DIV/0!	0.5	2619	2656	2588	2621
1	86	188	172	148.67	1				#DIV/0!	1	734	727	741	734
2.5	98	294	311	234.33	2.5				#DIV/0!	2.5	275	284	282	280.333333
5	53	125	168	115.33	5				#DIV/0!	5	25	11	25	20.3333333
10	26	91	98	71.67	10				#DIV/0!	10	7	17	13	12.3333333
Temp	73.1			73.1	Temp					Temp	79			79
RH	41.5			41.5	RH					RH	34.9			34.9

WLM 05/15/18

Building	RM #			Time	Building	RM #			Time	Building	RM #			Time
WLM	310	310	310	13:46-13:51	WLM	311B	311B	311B	13:52-13:59	WLM	314	314	314	13:58-14:03
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	18680	18683	17934	18432	0.3	18674	18600	18195	18490	0.3	18547	18648	18380	18525
0.5	664	755	678	699	0.5	589	631	669	630	0.5	665	697	803	722
1	138	176	161	158	1	92	95	129	105	1	133	148	179	153
2.5	67	136	173	125	2.5	36	60	88	61	2.5	65	133	167	122
5	19	47	54	40	5	4	9	26	13	5	18	45	48	37
10	17	49	70	45	10	15	19	41	25	10	15	34	46	32
Temp	72.6			72.6	Temp	72.4			72.4	Temp	72.7			72.7
RH	35.2			35.2	RH	35.7			35.7	RH	35.4			35.4

Building	RM #			Time	Building	RM #			Time	Building	RM #			Time
WLM	232	232	232	14:20-14:25	WLM	123	123	123	14:28-14:34	WLM	Roof	Roof	Roof	14:11-14:16
	Sa1	Sa2	Sa3			Sa1	Sa2	Sa3			Sa1	Sa2	Sa3	
0.3	21276	21358	22380	21671	0.3	17457	17961	18178	17865	0.3	52619	55860	57071	55183
0.5	826	866	969	887	0.5	678	716	732	709	0.5	3275	3450	3845	3523
1	147	172	192	170	1	112	148	144	135	1	997	1130	1143	1090
2.5	77	135	169	127	2.5	76	108	62	82	2.5	476	542	580	533
5	14	44	56	38	5	12	42	22	25	5	58	58	74	63
10	14	35	59	36	10	9	24	23	19	10	19	21	24	21
Temp	75			75	Temp	72.6			72.6	Temp	87.5			87.5
RH	33.3			33.3	RH	34.4			34.4	RH	25.9			25.9